

10/07/2011

D-Shift

Johnson

1924 - Completed Shift Brief with D-Shift.

2145 - Moved Red Arrow on use of AP-020 pump to ATB-11-014, clearing Red Arrow, pg. 246 @ 0001.

0000 10/08/2011

D-Shift

Johnson

0453 - Relieved as CSM by R. Malhan. *R. Malhan*0453 - ASSUMED DUTIES of BO CSM. R. Malhan *R. Malhan*

0718 - CONDUCTED PRE-SHIFT BRIEF WITH A-SHIFT CSM.

1100 - IHT COMPLETED FLAMMABLE GDS CHECKS for AN farm, AP farm & SY farm. ALL TANKS ARE READING 0% LFL.

o NEXT AP farm SR 3.1.1 DUE NLT 10/23/11 @ 0958 hrs

o NEXT AN farm SR 3.1.1 DUE NLT 10/28/11 @ 0730 hrs

o NEXT SY farm SR 3.1.1 DUE NLT 11/11/12 @ 0852 hrs

o NEXT AN farm SR 3.1.1 DUE NLT 10/23/11 @ 0958 hrs

1640 - Relieved as BO CSM by Blm Johnson. R. Malhan *R. Malhan*1640 - Reviewed logbook, assumed duties of CSM. *R. Malhan*

1915 - Completed Shift Brief with D-Shift.

0000 10/09/2011

D-Shift

Johnson

SUNDAY -

0446 - Relieved as CSM by R. Malhan. *R. Malhan*0446 - ASSUMED DUTIES of BO CSM. R. Malhan *R. Malhan*

0719 - CONDUCTED PRE-SHIFT BRIEF WITH A-SHIFT CSM.

LOW TEMP FOR THIS MORNING WAS 46 °F.

0830 - IHT COMPLETED FLAM GDS CHECKS for AY & AZ farm.

ALL TANKS ARE READING 0% LFL.

o NEXT AY farm SR 3.1.1 DUE NLT 10/14/11 @ 0758 hrs

o NEXT AZ farm SR 3.1.1 DUE NLT 10/14/11 @ 0803 hrs

0850 - NETWORK OPERATION CENTRAL REPORTS POSSIBLE LOSS OF POWER TO THE NETWORK EQUIPMENT @ MO-TLY AREA NABU TRAIL.

0917 - CONTACTED ELEC UTILITIES TO VERIFY ELEC OUTAGE STATUS FOR 0850-HR LOC ENTRY.

1215 - TMA'S RELEASE AP-102 ANNULUS ENRAF 8090 IS SHOWING A STEADY INCREASE SINCE MIDNIGHT & IS IN ALARM. OTHER TWO ENRAFS ARE HOWEVER STADY & NOT IN ALARM. UNABLE TO FIND APC. VERIFIED PRIMARY TANK LEVEL HAS NOT CHANGED. DISPATCHED ERI TO VERIFY ENRAF FIELD READING.

1236 - ERI VERIFIED AP-102 ANNULUS ENRAF 8090 IS THE FIELD IS READING SAME AS TMA'S @ 0.26".

LHM
10/10/11